

DRAWING NUMBER

DRAWING NUMBER

DRAWING NUMBER

DRAWING NUMBER

DRAWING NUMBER

DRAWING NUMBER

NOTES  
1- PANEL RP1055 (480/201V) IS LOCATED AT COLUMNS 235/310. PROVIDE (1) 3P-25A CIRCUIT BREAKER IN SPACES 11, 13, 15

ELECTRIC TRANSFER ROOM - SEE DWG 105R-E2

PLUGMOLD #2000 WITH RECEPTS @ 1'-0" C-C

EXIST'G 1/2" C 4" x 1/2" 1/8" TO DISC SW IN ELEC. TRANSF ROOM

TO EXIST'G CMT RP1055 (13)

LIQUID SENSOR ALARM PACKAGE

EXISTING PANEL G5B1 120/208V

CKT #30 UP TO PLUGMOLD

PLUGMOLD #2000 WITH RECEPTS 15'-0" AFF MOUNT 2'-10" AFF

PLAN OF CONTROL DESK AT PRINTER SHELF SPACE No 7/B

PLAN OF CONTROL DESK AT PRINTER SHELF SPACE No 13

PLAN OF CONTROL DESK AT PRINTER SHELF SPACE No 5

TERMINATE SIGNAL OUTLETS IN WIREWAY OF DESK BELOW COUNTERTOP

PLUGMOLD #2000 WITH RECEPTS @ 1'-0" C-C LENGTH 15'-0" AFF. MOUNT @ 4'-4" AFF. ALTERNATE CIRCUITS

PLUGMOLD #2000 WITH RECEPTS @ 1'-0" C-C LENGTH 8'-0" AFF MOUNT @ 4'-6" AFF

DOWN TO RECEPT. CKT #24

PLUGMOLD #2000 WITH RECEPTS @ 1'-0" C-C LENGTH 8'-0" AFF MOUNT @ 4'-6" AFF

DOWN TO RECEPT. CKT #30